

Part No. MI63/10L

METER ISOLATION LOCK-OFF KIT

10KA



KEY FEATURES

- ▶ Meets SAPN Service and Instalation Rules Requirement (S&IR) Clause 7.5 - (S&IR) 7.5.1.2
- ▶ Meets the requirements of AS3000:2018 & AS/NZS 60695
- ▶ Accepted by ETSA Utilities & SA Power Networks locking device (6 mm Diameter Shackle Padlocks)
- ▶ Suitable for Meter Enclosure upgrades to ensure SAPN compliance
- ▶ Equipped with quality Schneider Miniature Circuit breaker (63A/10KA)
- ▶ 2 Pole Cover IP30 ABS, Fire Resistant, DIN Rail - Sealable
- ▶ Dimension: 40 x 150 x 100 mm Single Phase 63A/6kA

AUSTRALIAN MADE 1.5 POLE ISOLATOR COVER

Flame Retardant full compound ABS injection moulded plastic



Manufactured using ABSTRENE M450 R01 R03

Property	Test Method	Units	Value
Tensile @ Yeild(50mm/min)	ISP 527	Mpa	38
Glow Wire (960 C)	AS/NZS 60695	C	Pass
H.D.T (182MPa) @ 3.2 mm	ISO 75	C	68