

Part No. MI63/6L-3P
METER ISOLATION LOCK-OFF KIT



Meets SAPN Service and
 Installation Rules Requirement
 (S&IR) Clause 7.5 - (S&IR) 7.5.1.2
 Meets the requirements of
 AS3000:2018 & AS/NZS 60695

AUSTRALIAN MADE 4.0 POLE ISOLATOR COVER

Flame Retardant full compound ABS injection moulded plastic



Manufactured using ABSTRENE M450 R01 R03

Property	Test Method	Units	Value
Tensile @ Yeild(50mm/min)	ISP 527	Mpa	38
Glow Wire (960 C)	AS/NZS 60695	C	Pass
H.D.T (182MPa) @ 3.2 mm	ISO 75	C	68